



NYC DEPARTMENT OF ENVIRONMENTAL PROTECTION
 Asbestos Control Program
 59-17 Junction Boulevard, 8th Floor, Flushing, NY 11373
ASBESTOS ASSESSMENT REPORT



1. NYC DOB Job # (if applicable) _____ **Control Number: 1038931**
 2. Premise No. 425 Street Name East 86 Street Borough Manhattan Zip 10028
 3. AKA _____ Type of Facility Residence BIN 1050548 Block 01566 Lot 0010
 4. Building Owner DOUGLAS ELLIMAN PROPERTY MGT Address 675 THIRD AVENUE
 5. City New York State NY Zip 10017 Contact Person KAREL DEBOER
 6. Tel. # (212) 692-8451 Fax # _____ Email _____
 7. Description of the Entire Scope of Work
Install pipe scaffolding

8. I, TIMOTHY DONOHOE, have conducted an asbestos investigation on
Name of Certified Asbestos Investigator
08/16/2012 in accordance
Date(s)

with Sections 1-16 and 1-28 of the NYC DEP Asbestos Control Program Rules and declare that at said facility address, the

- a. portion(s) of the premises affected by the work is free of asbestos containing material (ACM).
- b. premise (or portions thereof) affected by the work contains 10 square feet or less or 25 linear feet or less of ACM.
Specify locations in section 9: Note: This material must be abated as a minor project in accordance with relevant provisions of the DEP Asbestos Rules.
- c. asbestos is present and will not be disturbed during construction activity. Specify the quantity and area where asbestos is present. Specify amount: 1600 sq. ft. _____ linear ft.
Specify locations (attach additional documents as necessary):
Roof perimeter, masonry openings, seams
- d. entire building is free of asbestos containing material (ACM).

9. RESULTS OF ASBESTOS BUILDING SURVEY:


| FLOOR | DESCRIBE SECTION OF FLOOR | ALL MATERIALS ASSUMED TO CONTAIN ACM AND/OR SAMPLED | NUMBER OF SAMPLES ANALYZED | ASBESTOS PRESENT | ASSUMED ACM |
|-------|-------------------------------------|---|----------------------------|------------------|-------------|
| Roof | Perimeter | Roofing materials | 0 | Yes | Yes |
| All | Masonry openings and window lintels | Caulk waterproofing | 0 | Yes | Yes |
| 1st | Seams in concrete | Caulk | 0 | Yes | Yes |

10. ANALYTICAL LABORATORY:




| NAME | ELAP # (NYS DOH CERTIFICATION) | DATE(S) SAMPLES ANALYZED |
|------|--------------------------------|--------------------------|
| | | |

I hereby declare the information provided herein is true and complete

TIMOTHY DONOHOE 8/21/2012 116879 1/18/2014
DEP Certified Asbestos Investigator's Signature *Date* *Certificate Number* *Expiration Date*
 Tel. # (212) 260-9818 Fax # _____ Email t.donohoe@dvdenvironmental.com



The investigator shall assume that some or all of the areas investigated contain ACM, and for each area that is not assumed to contain ACM, collect and submit for analysis bulk samples in accordance with §§ 1-36, 1-37, and 1-44 of the DEP Asbestos Rules and EPA publications 560/5-85-024 and 560/5-85-030a and 40 CFR 763.86.



 DEPT. BLDGS. 121356077 Job Number 2541138
 SC120622033 Scan Code





NYC DEPARTMENT OF ENVIRONMENTAL PROTECTION
 Asbestos Control Program
 59-17 Junction Boulevard, 8th Floor, Flushing, NY 11373
ASBESTOS ASSESSMENT REPORT



11. NYS DOL Asbestos Handling license # 28545 Company Name DVD Environmental, Inc.

I hereby declare the information provided herein is true and complete

| | | | |
|--|-----------|-------------------------------|-----------------|
|  TIMOTHY DONOHOE | 8/21/2012 | 116879 | 1/18/2014 |
| DEP Certified Asbestos Investigator's Signature | Date | Certificate Number | Expiration Date |
| | | tdonohoe@dvdenvironmental.com | |
| Tel. # (212) 260-9818 | Fax # | Email | com |



The investigator shall assume that some or all of the areas investigated contain ACM, and for each area that is not assumed to contain ACM, collect and submit for analysis bulk samples in accordance with §§ 1-36, 1-37, and 1-44 of the DEP Asbestos Rules and EPA publications 560/5-85-024 and 560/5-85-030a and 40 CFR 763.86.

SEAL OF THE NYC DEP CERTIFIED ASBESTOS INVESTIGATOR



2541138